



Product Service

Attestation of Conformity

No. E8A 084937 0038 Rev. 00

Holder of Certificate: **Canadian Solar Inc.**

 545 Speedvale Ave West
 Guelph Ontario N1K1E6
 CANADA

Name of Object: **Converter**
Grid-connected photovoltaic inverter
Model(s): **CSI-4KTL1P-GI-FL, CSI-5KTL1P-GI-FL**
Description of Object:

 Input voltage: DC 90V~600V
 Max. input power: 4.6kW, 5.8kW
 Rated output voltage: AC 230V
 Rated frequency: 50Hz
 Rated output power: 4kW, 5kW
 Protection class: I

Tested according to:

 EN 61000-6-2:2005
 EN 61000-6-3:2007/A1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 4812820009900

Date, 2020-06-17

(Jun Bao)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.